

September 22, 2021

Mr. Scott Goldin
Goldin Metals, Inc.
12440 Seaway Road
Gulfport, MS 39503

Re Wind Load Review and Certification for 26 Ga., 36" Coverage, PBR Goldin Roof Panel over Steel Framing

Dear Mr. Goldin:

This is to advise you I have reviewed the technical data compiled and presented in a Product Evaluation Report by Terrence E. Wolf, P. E. dated June 29, 2021, regarding the testing and certification of your 26 Ga., 36" Coverage, PBR Goldin Roof Panels.

This report investigates the wind load capability of these roof panels attached to 16 Ga. minimum thickness steel framing. This report was compiled to validate the material's compliance with the 2018 International Building Code for wind pressure uplift and as listed in the report.

Based upon my evaluation and analysis of this data, it is my professional opinion the 26 Ga., 36" Coverage, PBR Goldin Roof Panel attached to 16 Ga. minimum thickness steel framing will meet the wind load requirements for the State of Mississippi for ultimate wind speeds up to 180 MPH as applied by ASCE 7, Wind Load Analysis.

The panels should be attached as detailed in the referenced Product Evaluation Report.

Should you have any questions or need additional information please do not hesitate to contact me @ 860-5318.

Sincerely yours,



Robert J. Knesal, P. E.

